

GLOBAL REFRIGERANTS (S) PTE LTD



CERTIFICATE OF ANALYSIS

Sample Name : R134A/900Gram **Contract No.** : GL22-14491
Sample Source : CAN **Sampling Time** : 12/10/2022
Product Standard : ARI 700 **Certificate Date** : 12/10/2022

Density items	Standard Demands	Results
APPEARANCE	CLEAN TRANSPARENT COLORLESS LIQUID	
PURITY,%	≥99.5	99.94
MOISTURE, %	≤0.002	0.0012
ACIDITY (AS HCL), %	≤0.0001	<0.0001
EVAPORATION RESIDUES, %	≤0.01	0.0006
Product amount: 20.196MT	FINAL conclusion: Conformity	
Tester: Chen Fei Wei Checker: XUDONGBO Auditor: XUYIHONG		

Registered Office

9 Tuas Link 1, Singapore 638587 • Telephone: +65 6863 3983 • Telefax: +65 6863 6330 • Email: globalref@singnet.com.sg