



GLOBAL REFRIGERANTS (S) PTE LTD



CERTIFICATE OF ANALYSIS

Sample Name : R23
Sample Source : CYLINDER
Product standard : ARI 700

Contract No. : GL22-14510
Sampling time : 10/11/2022
Certificate Date : 10/11/2022

Density items	Standard Demands	Results
APPEARANCE	CLEAN TRANSPARENT COLORLESS LIQUID	
PURITY, %	≥99.5	99.98
MOISTURE, %	≤0.002	0.00082
ACIDITY (AS HCL), %	≤0.0001	<0.0001
EVAPORATION RESIDUES, %	≤0.01	0.0008
Product amount: 1.719MT	FINAL conclusion: Conformity	
Tester: WUHAO Checker: WULONGFEI Auditor: XVGUANGJUN		

Registered Office

9 Tuas Link 1, Singapore 638587 • Telephone: +65 6863 3983 • Telefax: +65 6863 6330 • Email: globalref@singnet.com.sg