



GLOBAL REFRIGERANTS (S) PTE LTD



CERTIFICATE OF ANALYSIS

Sample Name : R404A
 Sample Source : CYLINDER
 Batch No : GL2209113
 Product Standard : ARI 700

Contract No. : GL22-14525
 Sampling Time : 05/12/2022
 Certificate Date : 05/12/2022

Density items	Standard Demands	Results
APPEARANCE	CLEAN TRANSPARENT COLORLESS LIQUID	
HFC-143a,%	52±1	52.4
HFC-125, %	44±1	43.7
HFC-134a, %	4±1	3.9
PURITY, %	≥99.5	99.99
MOISTURE, %	≤0.002	0.00082
ACIDITY (AS HCL), %	≤0.0001	<0.0001
EVAPORATION RESIDUES, %	≤0.01	0.0008
Product amount: 4.36MT	FINAL conclusion: Conformity	
Tester: Chen Fei Wei Checker: XUDONGBO Auditor: XUYIHONG		

Registered Office