


GLOBAL REFRIGERANTS (S) PTE LTD



CERTIFICATE OF ANALYSIS

Sample Name : R410A
Sample Source : CYLINDER
Batch No : GL220842
Product Standard : ARI 700

Contract No. : GL22-14525
Sampling Time : 01/12/2022
Certificate Date : 01/12/2022

Density items	Standard Demands	Results
APPEARANCE	CLEAN TRANSPARENT COLORLESS LIQUID	
HFC-32,%	49.5±1	49.7
HFC-125, %	50.5±1	50.3
Purity, %	≥99.5	99.99
MOISTURE,%	≤0.002	0.00084
ACIDITY (AS HCL), %	≤0.0001	<0.0001
EVAPORATION RESIDUES, %	≤0.01	0.0007
Product amount: 9.04MT	FINAL conclusion: Conformity	
Tester: GONGZHEWEI Checker: WUHAO Auditor: XVGUANGJUN		

Registered Office

9 Tuas Link 1, Singapore 638587 • Telephone: +65 6863 3983 • Telefax: +65 6863 6330 • Email: globalref@singnet.com.sg