


GLOBAL REFRIGERANTS (S) PTE LTD



CERTIFICATE OF ANALYSIS

Sample Name : R507
Sample Source : CYLINDER
Batch No : GL2209113
Product Standard : ARI 700

Contract No. : GL22-14525
Sampling Time : 06/12/2022
Certificate Date : 06/12/2022

Density items	Standard Demands	Results
APPEARANCE	CLEAN TRANSPARENT COLORLESS LIQUID	
HFC-125,%	50.5±1	50.6
HFC-143a, %	49.5±1	49.4
PURITY, %	≥99.5	99.99
MOISTURE,%	≤0.002	0.00084
ACIDITY (AS HCL), %	≤0.0001	<0.0001
EVAPORATION RESIDUES, %	≤0.01	0.0008
Product amount: 4.52MT	FINAL conclusion: Conformity	
Tester: GONGZHEWEI Checker: WUHAO Auditor: XVGUANGJUN		

Registered Office