

GLOBAL REFRIGERANTS (S) PTE LTD



CERTIFICATE OF ANALYSIS

Sample Name	: R407C	Contract No.	: GL22-14536
Sample Source	: CYLINDER	Sampling Time	: 14/01/2023
Batch No	: GL220910	Certificate Date	: 14/01/2023
Product Standard	: ARI 700		

Density items	Standard Demands	Results
APPEARANCE	CLEAN TRANSPARENT COLORLESS LIQUID	
HFC-32, %	23±2	22.4
HFC-125, %	25±2	24.8
HFC-134a, %	52±2	52.8
PURITY, %	≥99.5	99.93
MOISTURE,%	≤0.002	0.0009
ACIDITY (AS HCL), %	≤0.0001	<0.0001
EVAPORATION RESIDUES, %	≤0.01	≤0.005
Product amount: 2.26MT	FINAL conclusion: Conformity	
Tester: GONGZHEWEI		
Checker: WUHAO		
Auditor: XVXIAOYE		

Registered Office