


# GLOBAL REFRIGERANTS (S) PTE LTD



## CERTIFICATE OF ANALYSIS

Sample Name : R417A  
 Sample Source : CYLINDER  
 Batch No : GL2209101  
 Product Standard : ARI 700

Contract No. : GL22-14536  
 Sampling Time : 17/01/2023  
 Certificate Date : 17/01/2023

Density items	Standard Demands	Results
APPEARANCE	CLEAN TRANSPARENT COLORLESS LIQUID	
HFC-600, %	3.0~3.5	3.3
HFC-125,%	46.6±1.1	47.3
HFC-134,%	50±1	49.4
PURITY,%	≥99.5	99.9
MOISTURE, %	≤0.002	0.0009
ACIDITY (AS HCL), %	≤0.0001	<0.0001
EVAPORATION RESIDUES, %	≤0.01	<0.005
Product amount: 2.26MT	FINAL conclusion: Conformity	
Tester: WANGLASHI Checker: HELIANG Auditor: LIQIZHEN		

Registered Office