

CERTIFICATE OF ANALYSIS

Product XR 534-32

Lot Number 02012109C

	RESULTS	SPECIFICATIONS	METHOD
VISCOSITY @ 40°C, cSt	32.3	28.8 – 35.2	ASTM D445
TAN, mg KOH/g	0.02	≤ 0.10	ASTM D974
WATER CONTENT, ppm	30	≤ 50	ASTM D1533
DENSITY, kg/L @ 15°C	0.99	--	ASTM D7777
FOAM, mL	N/A	N/A	ASTM D892 (II)

Certified by: *Bryan Dole*

06/02/2022

QUALITY CONTROL

DATE