



# GLOBAL REFRIGERANTS (S) PTE LTD



## CERTIFICATE OF ANALYSIS

Sample Name : R600A  
 Sample Source : CAN  
 Product Standard : ARI 700

Contract No. : GL22-14536  
 Sampling Time : 03/02/2023  
 Certificate Date : 03/02/2023

Density items	Standard Demands	Results
APPEARANCE	CLEAN TRANSPARENT COLORLESS LIQUID	
Purity, %	≥99.5	99.9
MOISTURE, ppm by weight	≤0.002	0.002
ACIDITY (AS HC1), ppm	≤0.0001	<0.0001
EVAPORATION RESIDUES, %	≤0.01	<0.005
Product amount: 1.08MT	FINAL conclusion: Conformity	
Tester: Chen Fei Wei Checker: XUDONGBO Auditor: XUYIHONG		

Registered Office