



# GLOBAL REFRIGERANTS (S) PTE LTD



## CERTIFICATE OF ANALYSIS

Sample Name : R290  
 Sample Source : CAN  
 Product Standard : ARI 700

Contract No. : GL22-14405  
 Sampling Time : 29/06/2022  
 Certificate Date : 29/06/2022

Density items	Standard Demands	Results
APPEARANCE	CLEAN TRANSPARENT COLORLESS LIQUID	
Purity, %	≥99.5	99.9
MOISTURE, ppm by weight	≤0.002	0.0018
ACIDITY (AS HCL), ppm	≤0.0001	<0.0001
EVAPORATION RESIDUES, %	≤0.01	<0.01
Product amount: 0.6MT	FINAL conclusion: <b>Conformity</b>	
Tester: Chen Fei Wei Checker: XUDONGBO Auditor: XUYIHONG		

Registered Office

9 Tuas Link 1, Singapore 638587 • Telephone: +65 6863 3983 • Telefax: +65 6863 6330 • Email: globalref@singnet.com.sg